

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 4485-1332:0117

Page 1 of 1

CATEGORY: 4485 -- OPENING PROTECTION (FIRESTOPPING)

LISTEE: SPECIFIED TECHNOLOGIES 210 Evans Way, Somerville, NJ 08876
Contact: James Vail (908) 526-8000 Fax (908) 231-8415
Email: dvail@stifirestop.com

DESIGN: EZ-Path® Fire Rated Pathway firestop device consisting of a galvanized steel tube with built-in fire and smoke sealing system that automatically adjusts to the amount of penetrants installed allowing for a visual fill ranging between 0 and 100% providing a maintenance free solution. Brackets and associated hardware allow for devices to be installed individually or ganged together to increase loading capacity. Refer to listee's product data sheet and UL Fire Resistance Directory for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, UL Fire Resistance Directory, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, type identification and UL label.

APPROVAL: Listed as ½-hour, 1-hour, 2-hour, 3-hour, 4-hour fire-rated firestop systems for through-penetration firestop systems when installed in accordance with the UL Fire Resistance Directory. Refer to UL Fire Resistance Directory for detailed information for the specific assembly. Through-Penetration Firestop Systems: C-AJ-3214, C-AJ-3260, F-A-3015, F-A-3021, F-A-3026, F-A-3037, F-A-3054, F-A-3056, W-J-3130, W-L-3218, W-L-3248, W-L-3306, W-L-3377.

NOTE: Formerly 4485-1332-0101

03-13-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division